

FOI17 161 Raw Data

Ref	Incident date	Category	Actual Impact	Potential	Area / Department	Description	Action taken	Investigation
WF52472	05/12/2016	Utility Failure (Water, Electricity, Gas)	MINOR	MOD	Endoscopy Unit	significant leak from decontamination waste pipe causing flooding on level A outpatient department. Endoscopy department out of action for 2.5 days resulting in 12 cancelled lists and fast track patient breaches	Estates aware and assessed damage. Evening endoscopy lists cancelled for that evening	<p>Loss of 12 Endoscopy lists over 1 evening and 2 subsequent days.</p> <p>Unable to accommodate 10 cancer fast track patients as a consequence who will breach their 2 week wait.</p> <p>Outpatients department also damaged due to the leak, they have had a deep clean and ceiling tiles replaced.</p> <p>48 hr report completed</p> <p>48 hr report underway. 15/12/16 Emailed for update on 48 hour report 15/12/16 48 hour report received and sent to HONQ for review 29/12/16 All repairs are completed and the unit is running as per normal now . Severity downgraded as this unlikely to reoccur .HONQ</p>